



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hall Street 45, Essendon
45 Hall Street Essendon
Contract No: 3013

Callouts ID:

Date of Call: 25-10-2018 18:00:00
Time of Arrival: 25-10-2018 19:00:00
Rectification Time: 25-10-2018 20:20:00
Time of Departure: 25-10-2018 20:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 1

Call Description: Lift doors not closing

Order Number: 15327

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Light ray unit on doors is faulty. Checked leads and unit, organise for unit to be replaced first thing tomorrow morning.

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

.