



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Metro Ormond

Metro Ormond ormond

Contract No: P3622

Maintenance ID:

Date of Call: 23-10-2018

Time of Arrival: 12:00:00

Time of Departure: 14:45:00

Maintenance Details

Maintenance Description: Water in pit of lift 4

Maintenance Task	1	2	3	4
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y	Y
Test all car safties	Y	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y	Y
Check tuning ajustments	Y	Y	Y	Y
Lubricate All Sheaves	Y	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y	Y
Check and ajust car & cwt guide shoes	Y	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y	Y
check brake operation rope brake and associated equipment	Y	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y	Y
Check trailer flexes, attachments running clearance	Y	Y	Y	Y
Check and ajust top and bottom of all car and SWT rails	Y	Y	Y	Y
Test Emergency Light Unit	Y	Y	Y	Y
Test Lift Communications	Y	Y	Y	Y

Service Technician

Kevin Wilkins

Customer Email