



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Pegasus Suites Hotel
206-216 A'Beckett St Melbourne
Contract No: P3382

Callouts ID:

Date of Call: 23-10-2018 20:21:00
Time of Arrival: 23-10-2018 20:50:00
Rectification Time: 23-10-2018 21:20:00
Time of Departure: 23-10-2018 21:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 23

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Inverter error\r\nError 45 on inverter \r\nAdjust inverter parameters and autotune\r\nTest operation\r\nAll ok

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer