

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Nelson Place 235, Williamstown
235 Nelson Place Williamstown
Contract No: P3467

Callouts:

Date of Call: 18-12-2018 18:00:00 Time of Arrival: 18-12-2018 18:50:00 Rectification Time: 18-12-2018 7:04:00 Time of Departure: 18-12-2018 7:14:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 1,2
For Floor(s): g

Call Description: Lift sqeilling down the shaft not sure which lift

Order Number: 16237

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): No fault Found

Work Description: Rode both lifts up and down listening for noise, no noise found also ran the lifts from the motor room no noise found

Part Required: No Parts Required

Service Technician Report Customer

Dwain Sanderson