



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Living & Learning INC
6B Henry Street Pakenham
Contract No: P3488

Callouts: 22240

Date of Call: 09-11-2018 14:24:53
Time of Arrival: 09-11-2018 8:15:00
Rectification Time: 09-11-2018 8:20:00
Time of Departure: 09-11-2018 8:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): top floor

Call Description: Lift is stuck on the top floor. doors can open but won't move. Have tried to reset but still does not work.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found photocell lock ring missing causing misalignment of sensor. Replace lock ring, align and test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

Linda 5941 2389 5940 1016