



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Box Hill Town Hall
1022 Whitehorse Rd Box Hill
Contract No: 3472 - B505

Maintenance:

Date of Call: 04-01-2019
Time of Arrival: 14:53:00
Time of Departure: 14:53:00

Maintenance Details

Maintenance Description: Regular service \r\nLift 1 requires repair to ram and is shut down.

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Test all car safties	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Check tuning ajustments	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y
Check and ajust car & cwt guide shoes	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Check trailer flexes, attachments running clearance	Y	Y	Y
Check hydrolic tank oil level, valves RAM etc	Y	Y	Y
Test Emergency Light Unit	Y	Y	Y
Test Lift Communications	Y	Y	Y

Service Technician

Zane Tregurtha

Customer Email

caroline@unitedlifts.com.au