



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elizabeth St 191, Richmond (Building B)
191 Elizabeth St Richmond (Building B)
Contract No: P3547

Callouts ID: 21980

Date of Call: 12-10-2018 11:24:52
Time of Arrival: 12-10-2018 11:40:00
Rectification Time: 12-10-2018 12:00:00
Time of Departure: 12-10-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): ground

Call Description: between level doors open and close

Order Number: 15115

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift stopped above floor level, car doors opened but were not in mesh. Cleaned inductors, reset lift, monitored. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

Jade