



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Parliament House
100 Spring St East Melbourne
Contract No: P3058

Maintenance:

Date of Call: 27-11-2018
Time of Arrival: 9:55:00
Time of Departure: 11:15:00

Maintenance Details

Maintenance Description: Replaced faulty electrical striker on top landing door and tested operation

Maintenance Task	1	2	3	4	5
					Y

180 on line C:\xampp\htdocs\melbournemrs\html\maintenancePrint.php: Undefined offset: 0 in Notice

Service Technician

Graeme Gathercole

Customer Email

andrew.gaff@parliament.vic.gov.au