



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Lt Bourke 451, Melbourne  
451 Lt Bourke Melbourne  
Contract No: P3040

**Callouts: 22482**

Date of Call: 05-12-2018 8:41:28  
Time of Arrival: 05-12-2018 9:30:00  
Rectification Time: 05-12-2018 9:50:00  
Time of Departure: 05-12-2018 9:55:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Button/Indicator Not Working

**For Lift(s):** 1

**For Floor(s):** 7

**Call Description:** level 7 down arrow button not always working, increase sensitivity

**Order Number:** CWO0240458

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Changed contacts on back of down button tested ok.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

thomas