



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

ANZAC House  
4 Collins St Melbourne  
Contract No: P3085

## Maintenance:

Date of Call: 18-12-2018  
Time of Arrival: 8:50:00  
Time of Departure: 11:40:00

### Maintenance Details

**Maintenance Description:** Maintenance

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y
Check and ajust car & cwt guide shoes	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Check hydrolic tank oil level, valves RAM etc	Y	Y	Y
Test Lift Communications	Y	Y	Y

**Service Technician**

Graeme Gathercole

**Customer Email**

property@alexrobertson.com.au