



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Epping
Metro Epping Station Epping
Contract No: 3590

Callouts ID:

Date of Call: 19-10-2018 17:05:00
Time of Arrival: 19-10-2018 18:05:00
Rectification Time: 19-10-2018 21:00:00
Time of Departure: 19-10-2018 21:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): g

Call Description: Gap in door jam patent complained childs hand was stuck in gap.

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Left front car door had been knocked on left side warping door and damaging door guide.\r\nAdjust second guide and bend doors to not scrap
adjust so gap is minimised.\r\nNew door guides to be installed monday.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0