



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Toomah Community Centre
18 Golden Green Street Pakenham
Contract No: P3488

Callouts:

Date of Call: 11-12-2018 9:00:00
Time of Arrival: 11-12-2018 9:00:00
Rectification Time: 20-12-2018 10:10:00
Time of Departure: 11-12-2018 10:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): G

Call Description: Swing door not closing at lower level

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lower door not closing due to catching on the top of the door frame. Adjusted door and tested operation- ok. \r\n\r\nWill reccomend to Campaigne Group that some reference points be taken on the lift shaft to make sure there is no movement over time after termites were found in the adjacent wall

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.