



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Albert Redevelopment
140 Albert Road South Melbourne
Contract No: W3688

Callouts: 22436

Date of Call: 29-11-2018 13:13:05
Time of Arrival: 29-11-2018 14:15:00
Rectification Time: 29-11-2018 14:35:00
Time of Departure: 29-11-2018 15:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 1

Call Description: number panel lights are flickering

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Running on arrival concrete piece on door track. Concrete dust on locks. Cleaned and adjusted ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

David Ellis - 0414 324 894