



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Ginifer station
0 St Albans Road Ginifer
Contract No: P3639

Callouts:

Date of Call: 11-12-2018 23:07:00
Time of Arrival: 11-12-2018 23:35:00
Rectification Time: 11-12-2018 23:50:00
Time of Departure: 12-12-2018 0:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 1

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Replace Door/Lock Component

Work Description: Released passengers \r\nLift displaying recall when on normal\r\nFound.high resistant contact on recall switch\r\nSwap contact over

Part Required: Nc contact block for recall switch

Service Technician

Matt Grieger

Report Customer