



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Jones Lang LaSalle
401 Collins St Melbourne
Contract No: P3216

Callouts: 22291

Date of Call: 15-11-2018 9:48:23
Time of Arrival: 15-11-2018 10:05:00
Rectification Time: 15-11-2018 12:50:00
Time of Departure: 15-11-2018 13:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): 9

Call Description: service lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift stopped on level 9 100mm below floor level.\r\nchecked error logs\r\nsuspected power supply fault\r\nchecked and adjusted 24volt output voltage, need to investigate further\r\nreturned lift back to service \r\nto be inspected further on saturday 17th of November, \r\nnotified building manager.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Saju (JLL) 0435738090