

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Metro Watergardens
0 Sydenham Rd Sydenham
Contract No: P3679

Callouts: 22728

Date of Call: 28-12-2018 11:09:15 Time of Arrival: 28-12-2018 12:10:00 Rectification Time: 28-12-2018 12:15:00 Time of Departure: 28-12-2018 12:40:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out of order on ground floor

Order Number: 02AA604223

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Check Operation

Work Description: Error 54\r\nCheck and clean door tracks and car door locks\r\nTest operation

Part Required: No Parts Required

Service Technician

**Report Customer** 

Matt Grieger