



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Jolimont Rd 102-104, East Melbourne
102-104 Jolimont Rd East Melbourne
Contract No: P3233

Maintenance:

Date of Call: 07-12-2018
Time of Arrival: 9:10:00
Time of Departure: 9:50:00

Maintenance Details

Maintenance Description: Small amount of water found in pit. Supervisor notified.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safeties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Test Lift Communications	Y

Service Technician

Nathan Downton

Customer Email

mari@strata-connect.com.au