



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Franklin St 50, Melbourne
50 Franklin St Melbourne
Contract No: P3301

Callouts: 22159

Date of Call: 01-11-2018 10:42:28
Time of Arrival: 01-11-2018 14:05:00
Rectification Time: 01-11-2018 15:05:00
Time of Departure: 01-11-2018 16:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: lift out of order on level 2

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Light rays damaged streighten light rays and clean re set fault log test run \r\nNew light rays required

Part Required:

Service Technician

Phil Dodsworth

Report Customer

yes