



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Metro Nunawading**

Metro Nunawading Station Nunawading

Contract No: P3586

## Callouts:

Date of Call: 02-12-2018 21:27:00  
Time of Arrival: 02-12-2018 22:00:00  
Rectification Time: 02-12-2018 22:30:00  
Time of Departure: 02-12-2018 23:00:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** G

**Call Description:** Lift stopped over top floor.

**Order Number:** 659074

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Check slow downs and leveling devices. Reset pit safety and return to service.

**Part Required:** No Parts Required

**Service Technician**

Daniel Barry

**Report Customer**

.