



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

City Gate Hotel/Doubletree
270 Flinders St Melbourne
Contract No: P3103

Callouts: 22678

Date of Call: 20-12-2018 11:26:07
Time of Arrival: 20-12-2018 11:45:00
Rectification Time: 20-12-2018 14:35:00
Time of Departure: 20-12-2018 14:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): Ground

Call Description: lift 4 is stuck on the ground floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Open circuit KAD1 lock circuit cleaned and checked locks all floors adjusted ground floor bridging piece, cleaned CDS

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

.