

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Pran Central Apartments
220 Commercial Rd Prahran
Contract No: P3279

Callouts: 22272

Date of Call: 13-11-2018 15:07:11 Time of Arrival: 13-11-2018 15:00:00 Rectification Time: 13-11-2018 15:30:00 Time of Departure: 14-11-2018 15:34:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1,2 For Floor(s): 5

Call Description: one lift the doors wont shut, and the other lift is not going to any of the levels

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: Reported both both lift 1 and 2 000 \r\nUpon arrival lift 2 running and lift one stopped level 5 doors open, cleaned out door tracks and checked locks, returned to service\r\nTested operation

Part Required: No Parts Required

Service Technician Report Customer

Dwain Sanderson