

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
City Gate Hotel/Doubletree
270 Flinders St Melbourne
Contract No: P3103

## Callouts ID: 22064

Date of Call: 22-10-2018 12:01:25 Time of Arrival: 22-10-2018 12:20:00 Rectification Time: 22-10-2018 12:40:00 Time of Departure: 22-10-2018 12:45:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 2
For Floor(s): 9

**Call Description:** light is lift 2 button level 9 is not lighting up

Order Number: .

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found connection fault on back light on car button level 9 repaired wiring checked operation ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle