



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Quartier

379 Wattletree road Armadale

Contract No: S3560

Callouts:

Date of Call: 17-12-2018 11:50:00
Time of Arrival: 17-12-2018 11:50:00
Rectification Time: 17-12-2018 12:50:00
Time of Departure: 17-12-2018 12:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): 1

Call Description: Lift has water in pit meet plumber to pump out.

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Pump water out. Water seeping through wall of pit (plumber also saw this).\r\nWorks for repairs required will organise quote \r\nLift back in service.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

P