



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Clayton Hotel
319 Clayton Road Clayton
Contract No: B3738

Callouts:

Date of Call: 16-11-2018 22:43:00
Time of Arrival: 16-11-2018 23:15:00
Rectification Time: 16-11-2018 23:30:00
Time of Departure: 16-11-2018 23:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): ground

Call Description: reported people and a baby stuck

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift 350mm above ground floor \r\nreleased passengers\r\nfire brigade on site on arrival.\r\nswitched lift off notified building manager.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Naomi