



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hub Arcade

318-322 Lt Collins St Melbourne

Contract No: P3352

Callouts: 22717

Date of Call: 27-12-2018 10:22:53
Time of Arrival: 27-12-2018 12:20:00
Rectification Time: 27-12-2018 13:00:00
Time of Departure: 27-12-2018 13:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: out of order.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Printed Circuit Board Faulty

Work Action (CORRECTION): Reset Control System

Work Description: Error code 35 checked KMB contactor no fault found. Relay on main board switching KMB holding up released relay and checked operation

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

Steve 0414977342