



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

La Trobe St 171, Melbourne  
171 La Trobe St Melbourne  
Contract No: P3391

## Callouts:

Date of Call: 12-11-2018 7:45:00  
Time of Arrival: 12-11-2018 8:25:00  
Rectification Time: 12-11-2018 8:55:00  
Time of Departure: 12-11-2018 9:20:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Closed

**For Lift(s):** 2

**For Floor(s):** 1

**Call Description:** Stopped on level 1 doors closed

**Order Number:** ?

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Lift on Exclusive or Fire Service

**Work Action (CORRECTION):** Reset/Adjust Switch

**Work Description:** Lift switched to independent and inspection at main COP reset inspection to off position and marked switch Do Not Use

**Part Required:** No Parts Required

**Service Technician**

Graeme Gathercole

**Report Customer**

-