



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts: 22546

Date of Call: 10-12-2018 14:43:30
Time of Arrival: 10-12-2018 14:50:00
Rectification Time: 10-12-2018 14:55:00
Time of Departure: 10-12-2018 15:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 2

Call Description: 7 people stuck in lift between G-2

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Main Circuit Braker Tripped

Work Action (CORRECTION): Reset Control System

Work Description: Main circuit breaker tripped. Reset circuit breaker.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

0434848085