



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro St Albans Station
Main Road St Albans Road St Albans
Contract No: P3638

Callouts:

Date of Call: 16-11-2018 20:26:00
Time of Arrival: 16-11-2018 21:05:00
Rectification Time: 16-11-2018 22:14:00
Time of Departure: 16-11-2018 22:19:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 1

Call Description: 1 passenger stuck in lift

Order Number: 659238

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: passenger out of lift on arrival by fire department,\r\nerror 54 bottom landing door fault\r\nchecked landing door locks\r\nntested ok checked operation returned lift back to service.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

steve