



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts:

Date of Call: 29-12-2018 13:55:00
Time of Arrival: 29-12-2018 14:09:00
Rectification Time: 29-12-2018 14:20:00
Time of Departure: 29-12-2018 14:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 6

Call Description: Passenger stuck.

Order Number: 16372

DESCRIPTION OF WORK

Fault Found (CAUSE): Rope Brake Tripped

Work Action (CORRECTION): Reset Control System

Work Description: Rope brake tripped, level 6. Reset and check locks and safeties. Monitor.

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

.