



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

**Tower 2**

60 Lorimer Street Docklands

Contract No: P3671

## Maintenance:

Date of Call: 28-11-2018

Time of Arrival: 11:00:00

Time of Departure: 12:15:00

### Maintenance Details

**Maintenance Description:** Routine maintenance

Maintenance Task	E1	E2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check and ajust car & cwt guide shoes	Y	Y
Check all safety switches, limits in lift well	Y	Y
Check pit equipment and check water for pit	Y	Y
Clean lift well equipment	Y	Y
Test Lift Communications	Y	Y

**Service Technician**

Brad Stellini

**Customer Email**

steve@scaownerscorp.com.au