



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Hall St 40**

40 Hall Street Moonee Ponds

Contract No: W3776

**Callouts: 22767**

Date of Call: 03-01-2019 12:49:32  
Time of Arrival: 07-01-2019 8:06:00  
Rectification Time: 07-01-2019 10:06:00  
Time of Departure: 07-01-2019 11:06:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Playing Up

**For Lift(s):** Platform

**For Floor(s):** n/a

**Call Description:** Doors were previously reinstalled, now they are not locking and need to be realigned.\r\nReported by: Sam Cosentino 0467 063 161

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Adjusted door level, added spacers to bump stops, adjusted door magnet\r\nRun and tested. Returned to service

**Part Required:** No Parts Required

**Service Technician**

James Wallace

**Report Customer**

.