

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Bluesky - Flemington

1 Flemington Rd North Melbourne
Contract No: A3689

Callouts:

Date of Call: 17-11-2018 11:05:00 Time of Arrival: 17-11-2018 13:05:00 Rectification Time: 17-11-2018 13:30:00 Time of Departure: 17-11-2018 14:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2
For Floor(s): G

Call Description: Lift out of order

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): Reset Door Operator

Work Description: Onsite lift driver tripped lock after albeing absent. Tryed to access lift and did not reset door access device causing error 54 door deviation. R door device and returned to service

door de vice dita retained to ber vice

Part Required: No Parts Required

Service Technician Report Customer

Marek Torrico Onsite builder