



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Keilor Rd 74, Essendon
74 Keilor Rd Essendon
Contract No: P3330

Callouts:

Date of Call: 25-12-2018 10:38:00
Time of Arrival: 25-12-2018 11:40:00
Rectification Time: 25-12-2018 12:00:00
Time of Departure: 25-12-2018 12:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Door close protection timer elapsed error\r\nCar door panels out of adjustment\r\nSecond panel loose and bottoming out on door sil, not allow doors to close\r\nRe align and set up door panels\r\nTest operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer