



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Sargood House**  
61-73 Flinders Lane Melbourne  
Contract No: P3190

**Callouts ID: 21979**

Date of Call: 12-10-2018 11:08:38  
Time of Arrival: 12-10-2018 11:30:00  
Rectification Time: 12-10-2018 12:00:00  
Time of Departure: 12-10-2018 12:05:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** See Fault Description

**For Lift(s):** 3

**For Floor(s):** .

**Call Description:** sliding door is loose at the bottom basement of lift 3

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** car door rhs slow panel out of alignment\r\nreadjusted panel possibly pushed in,\r\nchecked operation ok.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Tim