



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

G.A.M. Steel
557 Mt Derrimut Rd Derrimut
Contract No: P3130

Maintenance:

Date of Call: 04-01-2019
Time of Arrival: 8:45:00
Time of Departure: 9:45:00

Maintenance Details

Maintenance Description: Routine service \r\nReplace emphone unit with new due to internal microphone issue\r\nTest ok

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check pit equipment and check water for pit	Y
Check hydrolic tank oil level, valves RAM etc	Y
Report any major rapirs	Y
Test Lift Communications	Y

Service Technician

Matt Grieger

Customer Email