



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro South Morang
Metro South Morang South Morang
Contract No: P3591

Callouts: 22138

Date of Call: 30-10-2018 15:13:12
Time of Arrival: 01-11-2018 8:49:00
Rectification Time: 01-11-2018 9:49:00
Time of Departure: 01-11-2018 10:49:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): G

Call Description: Emergency call button in lift is not working\r\nSite contact: Albina 9610 8210

Order Number: 657679

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Replaced station emphone, reprogrammed and checked all emg dialing procedure

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#