

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Queens Road 71
71 Queens Road Melbourne
Contract No: P3645

Callouts: 22543

Date of Call: 10-12-2018 13:32:19 Time of Arrival: 10-12-2018 14:00:00 Rectification Time: 10-12-2018 14:15:00 Time of Departure: 10-12-2018 14:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 2

For Floor(s): g

Call Description: Middle Lift. Ground floor button is not operating correctly.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Repaied ground floor button lift 2

Part Required: Button parts

Service Technician Report Customer

Brad Stellini email: 309567