



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Barristers Chambers 180 William St
180 William St Melbourne
Contract No: P3196

Callouts:

Date of Call: 22-11-2018 8:35:00
Time of Arrival: 22-11-2018 8:50:00
Rectification Time: 22-11-2018 9:45:00
Time of Departure: 22-11-2018 9:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 6

Call Description: lift 2 out of order on level 6

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Encoder error fault \r\nchecked encoder \r\nchecked connections\r\nchecked power supply voltages adjusted 5vdc line\r\nchecked operation.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Yuri