

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts: 22366

Date of Call: 22-11-2018 11:35:21 Time of Arrival: 22-11-2018 11:50:00 Rectification Time: 22-11-2018 11:55:00 Time of Departure: 22-11-2018 12:20:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 3

For Floor(s): 6

Call Description: Lift on the Left. person stuck in lift

Order Number: .

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Released S.W.P. Drive trip fault AOC checked associated circuit ran and tested

Part Required: No Parts Required

Service Technician Report Customer

Brad Stellini 0468957176