

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Wellington Street 240, Collingwood
240 Wellington Street Collingwood
Contract No: 3700

Callouts:

Date of Call: 09-12-2018 19:21:00 Time of Arrival: 09-12-2018 20:05:00 Rectification Time: 09-12-2018 22:35:00 Time of Departure: 09-12-2018 22:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground

Call Description: reported lift 1 empty - stuck on ground with doors shut

Order Number: 16006

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: SE fault checked inductor tape guides cleaned sensors tested ok

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Jayden