



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Maintenance:

Date of Call: 10-12-2018
Time of Arrival: 9:15:00
Time of Departure: 10:50:00

Maintenance Details

Maintenance Description: Remove and clean encoder, refit and adjust floor levels of lift 2.

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safeties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning adjustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check all safety switches, limits in lift well	Y	Y
check brake operation rope brake and associated equipment	Y	Y
Check pit equipment and check water for pit	Y	Y
Check trailer flexes, attachments running clearance	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Kevin Wilkins

Customer Email

LiftServices-02@jacobs.com