



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Victoria Hotel
215 Lt Collins St Melbourne
Contract No: P3234

Callouts: 22602

Date of Call: 14-12-2018 9:42:53
Time of Arrival: 14-12-2018 14:55:00
Rectification Time: 14-12-2018 15:35:00
Time of Departure: 14-12-2018 15:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 5

For Floor(s): 4

Call Description: Lift in East wing stuck on level 4

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: level 8 landing doors not closing \r\nadjusted landing door RHS panels \r\nntested ok.\r\n

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Nick 9669 0000