



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton  
141 Nicholson St Carlton  
Contract No: P3118

**Callouts: 22646**

Date of Call: 17-12-2018 14:08:49  
Time of Arrival: 17-12-2018 14:34:00  
Rectification Time: 17-12-2018 15:10:00  
Time of Departure: 17-12-2018 15:18:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** G

**Call Description:** lift is out of order with the doors shut on ground floor

**Order Number:** 16161

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Landing doors not closing fully closed. \r\nAdjusted landing door rollers.

**Part Required:** No Parts Required

**Service Technician**

Gavin Pedlar

**Report Customer**

x