

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 03 9687 9099 info@unitedlifts.com.au

Customer Details:
Knox City Apartments
337 Stud Rd / 400-408 Burwood Road Wantirna South
Contract No: P3244

Maintenance:

Date of Call: 12-11-2018 Time of Arrival: 15:10:00 Time of Departure: 16:00:00

Maintenance Details

Maintenance Description: Regular service \r\nLift logged no errors since last call out, checked inductor clearances again and inductors.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
check brake operation rope brake and assocated equipment	Y
Check pit equipment and check water for pit	Y
Check trailer flexes, attachments running clearance	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Customer Email

Zane Tregurtha

MarcusL@networkpacific.com.au