



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nelson Place 235, Williamstown
235 Nelson Place Williamstown
Contract No: P3467

Callouts:

Date of Call: 31-12-2018 20:49:00
Time of Arrival: 31-12-2018 21:10:00
Rectification Time: 31-12-2018 21:37:00
Time of Departure: 31-12-2018 21:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 8

Call Description: Lift OOO with passengers trapped

Order Number: 16382

DESCRIPTION OF WORK

Fault Found (CAUSE): Power Failure

Work Action (CORRECTION): See Work description

Work Description: Power outage. Power returns while onsite with fire brigade. Reset rope brake on lift 2, run and tested and returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.