



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Spring Road 12, Malvern
12 Spring Road Malvern
Contract No: P3743

Maintenance:

Date of Call: 16-11-2018
Time of Arrival: 9:10:00
Time of Departure: 10:31:00

Maintenance Details

Maintenance Description: Regular service \r\nLift 2 has 15-20mm of water in pit again since being pumped out

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning adjustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check and adjust car & cwt guide shoes	Y	Y
Check pit equipment and check water for pit	Y	Y
Check trailer flexes, attachments running clearance	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Zane Tregurtha

Customer Email

tony@allianceocm.com.au