



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro McKinnon
Metro McKinnon McKinnon
Contract No: P3623

Callouts: 22192

Date of Call: 05-11-2018 10:37:07
Time of Arrival: 05-11-2018 11:10:00
Rectification Time: 05-11-2018 11:10:00
Time of Departure: 05-11-2018 11:22:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 2

For Floor(s): G

Call Description: emergency audio inside lift is not working

Order Number: 658466

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Tested lift phones in both lifts 1 and 2, both working without issue as confirmed by the operator. Platform indicator not working part will be ordered, programmed and fitted asap.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.