



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Annecto - David House
0 Little David Street Yarraville
Contract No: B3522

Callouts ID: 21977

Date of Call: 12-10-2018 9:40:00
Time of Arrival: 12-10-2018 10:00:00
Rectification Time: 12-10-2018 10:00:00
Time of Departure: 12-10-2018 11:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: stuck on ground floor

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Smashed

Work Action (CORRECTION): See Work description

Work Description: Ground floor button pushed in on cop\r\nRelease button doors closed and lift took off\r\nNo fault found during testing

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer