



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Central Shopping Center

Cnr Crn 13-15 Lake Street & 218-222 Caroline Springs Boulevard Caroline Springs
Contract No: P3712

Maintenance ID:

Date of Call: 25-10-2018
Time of Arrival: 10:15:00
Time of Departure: 12:15:00

Maintenance Details

Maintenance Description: Lift 1 inductor fault below ground floor
Strip and clean and check magnets
Test operation all ok
Tighten up traveller
handrail tension
Test ok

Maintenance Task	L1	L2	L3	Esc 1	Esc 2
Contact Building Rep. Check Ride & Appointments.	Y			Y	
Test all car safeties	Y			Y	
Clean out controller and check operation of various parts.	Y			Y	
Clean & check landing door equipment	Y			Y	
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y			Y	
Check and adjust car & counterweight guide shoes	Y			Y	
Check all safety switches, limits in lift well	Y			Y	
Check pit equipment and check water for pit	Y			Y	
Test Emergency Light Unit	Y			Y	
Test Lift Communications	Y			Y	
Contact Building Rep, Check Ride and Appointments	Y			Y	
Test All Safeties	Y			Y	
Clean controller and check operation of various parts	Y			Y	
Check pit equipment and check for water in pit.	Y			Y	
Check and Clean newel rollers	Y			Y	
Report Major repairs	Y			Y	

Service Technician

Matt Grieger

Customer Email

KBurton@teskacarson.com.au