

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Eden Apartments
1 Acacia Place Abbotsford
Contract No: P3453

Callouts: 22702

Date of Call: 24-12-2018 12:01:31 Time of Arrival: 24-12-2018 12:12:00 Rectification Time: 24-12-2018 12:25:00 Time of Departure: 24-12-2018 12:35:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): \*

Call Description: Up Button is not working properly. Doors open into the hall when it should be.

Order Number: \*

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Up Button mechanism had broken, replaced button. Returned to service. Tested ok.

Part Required: Step button.

Service Technician Report Customer

Nathan Downton Harris (0448971433)